

Acton Municipal Utility District (AMUD) is committed to providing residents with a safe and reliable supply of high-quality drinking water. We test our water using sophisticated equipment and advanced procedures. Acton Municipal Utility District's water meets state and federal standards for both appearance and safety. This annual "Consumer Confidence Report," required by the Safe Drinking Water Act (SDWA), tells you where your water comes from, what our tests show about it and other things you should know about drinking water and AMUD.

OUR DRINKING WATER IS REGULATED

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

Where do we get our drinking water?

Acton Municipal Utility District is supplied by surface water from Lake Granbury. We also pump groundwater from the Trinity and Paluxy Aquifers through twenty-four water wells located throughout our District. These sources are blended throughout the system. The water from Lake Granbury is treated at the Brazos Regional Public Utility Agency SWATS Plant located on Matlock Road off of Highway 167.

SOURCES OF DRINKING WATER: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (1-800-426-4791).

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those

undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids, and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

Required Additional Health Information for Lead

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Acton Municipal Utility District is responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Source Water Assessment Protection: TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants may be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system, contact T J Riggio at 817-326-4720.

En Español

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (817) 326-4720.

Overview

In 2019, AMUD distributed more than 689 million gallons of water to our customers. AMUD has grown from 7,905 water connections in December 2018 to 8,249 water connections in December 2019. A number of improvements to our water system have been completed. AMUD added 69 new valves and 40 new fire hydrants to our water system during the year. AMUD installed approximately 23,406 linear feet of water pipe in Pecan Plantation and the Acton areas. These improvements will continue to provide our customers with an ample supply of potable water.

In the water loss audit submitted to the Texas Water Development Board for the time period of Jan - Dec 2019, our system lost an estimated 58,247,619 gallons of water. If you have any questions about the water loss audit, please call 817-326-4720.

Public Participation Opportunities

We encourage public interest and participation in our community's decisions affecting drinking water.

Regular Board Meetings occur on the third Wednesday of every month, at the District Office located at 6420 Lusk Branch Court, the meetings begin at 9:00 AM. The public is welcome.

Consult our Web Site at www.amud.com and/or contact us at (817) 326-4720, for further information, see U.S. Environmental Protection Agency (EPA) water information at www.epa.gov/safewater/.

T J Riggio provided information included in the water-quality table for the Consumer Confidence Report. For questions concerning Acton Municipal Utility District or our water quality, please call (817) 326-4720. Learn more about AMUD water system at www.amud.com.

DEFINITIONS and Abbreviations The following tables contain scientific terms and measures, some of which may require explanation.

Action Level The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Action Level Goal (ALG) The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Avg: Regulatory compliance with some MCLs are based on running annual average of monthly samples.

Level 1 Assessment A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.

Level 2 Assessment A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Maximum Contaminant Level or (MCL) The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal or (MCLG) The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLG's do not reflect the benefits of the use of disinfectants to control microbial contamination.

MFL - million fibers per liter (a measure of asbestos).

mrem - millirems per year (a measure of radiation absorbed by the body).
na: not applicable.

NTU - Nephelometric turbidity units (a measure of turbidity).

pCi/L - picocuries per liter (a measure of radioactivity).

ppb: micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.

ppm: milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.

ppq - parts per quadrillion, or pictograms per liter (pg/L).

ppt - parts per trillion, or nanograms per liter (ng/L).

Treatment Technique or TT - A required process intended to reduce the level of a contaminant in drinking water.

Disinfectant Residual

Year	Disinfectant Type	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Source in Drinking Water
2019	Chlorine and Chloramine	2.173	.05 - 5.3	4	4	ppm	N	Water additive used to control microbes.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90 th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	4/14/2018	1.3	1.3	0.11	0	ppm	N	Erosion of natural deposits; Leaching from wood preservatives; corrosion of household plumbing systems.
Lead	4/14/2018	0	15	2.2	0	ppb	N	Corrosion of household plumbing systems, erosion of natural deposits.

2019 Water Quality Test Results

Disinfection By-Products	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)	2019	13	0 - 20.4	No goal for the total	60	ppb	N	By-product of drinking water disinfection.

The value in the Highest Level or Average Detected column is the highest average of all HAAS sample results collected at a location over a year.

Total Trihalomethanes (TTHM)	2019	11	0 - 19.9	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
-------------------------------------	------	----	----------	-----------------------	----	-----	---	--

The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year.

Inorganic Contaminants

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Arsenic	2019	2.1	0 - 2.1	0	10	Ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes.
Barium	2019	0.066	0.019 - 0.066	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium	2019	1.6	1 - 1.6	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.
Cyanide	2019	28.4	28.4 - 28.4	200	200	ppb	N	Discharge from plastic and fertilizer factories; Discharge from steel/metal factories.
Fluoride	2019	0.525	0.525 - 0.525	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate (measured as Nitrogen)	2019	1.56	0.024 - 1.56	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Nitrite (measured as Nitrogen)	2019	0.117	0 - 0.117	1	1	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Individual Samples	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	08/31/2017	2.86	2.86 - 2.86	0	5	pCi/L	N	Erosion of natural deposits.
Gross alpha excluding radon and uranium	2019	3.1	3.1 - 3.1	0	15	pCi/L	N	Erosion of natural deposits.

Turbidity

Year	Contaminant	Highest Single Measurement	Lowest Monthly % of Samples Meeting Limits	Turbidity Limits	Unit of Measure	Source of Contaminant
2019	Turbidity	.31	99.187	0.3	NTU	Soil Runoff

Coliform Bacteria

Maximum Contaminant Level Goal	Total Coliform Maximum Contaminant Level	Highest No. of Positive	Fecal Coliform or E.Coli Maximum Contaminant Level	Total No. of Positive E.Coli or Fecal Coliform Samples	Violation	Likely Source of Contamination
0	1 positive monthly sample	1		0	N	Naturally present in the environment